











# IMPORTANT SAFETY PRECAUTIONS

Before you begin, read these instructions completely and carefully.

- Be certain electrical power is OFF before and during installation, maintenance and removal.
- · Luminaire wiring must be properly grounded in accordance with the NEC and any applicable local code requirements.
- Use only UL or IEC approved wire for input/output connections.
- · Verify that supply voltage matches voltage on luminaire label. Installation to any other connection may void the warranty.
- Wear gloves during installation to prevent injury and do not expose wiring to metal or sharp edges.
- Do not install in areas subject to combustible vapors or gases. Verify luminaire location ratings are suitable for installation environment (refer to specification sheet as needed).
- Do not restrict luminaire's ventilation by covering with material that will cause luminaire to overheat and potentially shorten the life span.
- · Ensure LED luminaire has the correct polarity before installation.





WARNING: To reduce the risk of personal injury or property damage from fire, electrical shock, falling parts, abrasions, burns and all other hazards, read all provided warnings and follow installation instructions.


This product should be installed, inspected and maintained by a qualified and licensed electrician. Installation of luminaire must be in accordance with NEC and local code requirements.

SAVE THESE INSTRUCTIONS




#### **DIMENSIONS**

### 4" Product




## 6" Product




## INSTALLATION INSTRUCTIONS

A) Turn off power before installation. Remove the existing bulb and if necessary remove the existing trim. Open the hole on the mounting surface according to the table below.


FIXTURE SIZE inches	4"	6"
HOLE SIZE inches	4-21/64"	6-19/64"




**B)** Open the j-box, connect the power cable,as shown below.



**C)** Connect the fixture power cable and the j-box, as shown below.



**D)** Install the fixture to ceiling surface, as shown below.



E) Installation is complete.

